



Date: 20th April 2006

Our ref.: —

Your ref.:

Příhoda s.r.o.
Za Radnicí 476
539 01 Hlinsko

Subject: Influence of product parameters on reaction to fire tests performance

The Influences of product parameters and end-use conditions on reaction to fire tests performance are fully described in a technical specification prCEN/TS 15117:2004 issued by European committee for standardization. On the basis of clause A.2 of this document can state the colour of the product and the colouring substance may the influence to the fire performance of the product, but if the change of composition by a colouring substance is negligible, the influence is negligible.

**Centrum
stavebního inženýrství a.s.**
Pražská 16, 102 21 Praha 10
IČ: 45274860
(44)

Vít Slaboch

Fire technical laboratory

Bank. spoj.: KB PRAHA 10
Číslo účtu: 2901-101/0100
IČ: 45274860
DIČ: CZ45274860

Provolba: 281 017 451
Spojovatelka: 281 017 111
Fax: 281 017 455
ptl@csias.cz
www.csias.cz